

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3295-1523:100

Page 1 of 1

CATEGORY: Fire-Rated Door

LISTEE: Special-Lite Inc., 88448 CR 668, Decatur, MI 49045
Contact: *Andy Seiser (616) 423-7068 Fax (800) 423-7610

DESIGN: Swinging type 20-minute fire door with foam core in maximum size of 4 ft. wide by 8 ft. high. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 80, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type, rating and UL label.

APPROVAL: Listed as a 20-minute fire-rated door when installed in a listed frame approved for the type of wall construction. Cutouts and mounting holes shall be made at the factory to accommodate field installation. Glass light shall not exceed 168 sq. in. per door with the width or height not exceeding 28 inches.

*Rev. 06-06-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager